

IEC**IECEE**

Ref. Certif. No.

FR_716966

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC electric vehicle conductive charging station

Name and address of the applicant

LEGRAND FRANCE
6, rue Paul Nouel
76770 MALAUNAY
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
6, rue Paul Nouel
76770 MALAUNAY
FRANCE

Name and address of the factory

LEGRAND FRANCE
6, rue Paul Nouel
76770 MALAUNAY
FRANCE

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

Green'up Premium IP55
References: see Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_715824 dated 2022/10/26.
Addition of alternative critical components. Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61851-1:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

13437431-775587-B V03

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCEwww.lcie.frLABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B-408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSESSignature: **Julien GAUTHIER**
Certification Officer

Date: 26/05/2023

ANNEX

Ratings and main characteristics

Equipment mobility	Stationary
Connection to the mains	Permanent connection
EV charging modes	Modes 1, 2 and 3
Type of EV connection	Case A, B
Access location	Restricted access location
Over voltage category	OVC III
Supply voltage	195 V to 265 V
Frequency	50/60 Hz
Class of equipment	Class I
Pollution degree	PD 3
IP protection class	IP 55

Product References

Green' up Premium IP55 metallic charging station									
Charging mode	Power	Number of charging points	Socket outlet			Rated Current Mode 2	Rated current Mode 3	Wall mounting	Free standing
			Mode 3	Mode 2					
				Type 2	GUA Franco/Belge				
Mode 2 & 3	3.7 kW 4.6 kW	1	1	2	-	16A	16A/20A Mono 0 580 10 + 0 590 53	0 580 10 + 0 590 54	
Mode 2 & 3	3.7 kW 4.6 kW	2	2	2	-	16A	16A/20A Mono 0 580 11 + 0 590 53	0 580 11 + 0 590 54	
Mode 2 & 3	5.7 kW 7.4 kW	1	1	2	-	16A	25A/32A Mono 0 580 12 + 0 590 53	0 580 12 + 0 590 54	
Mode 2 & 3	5.7 kW 7.4 kW	2	2	2	-	16A	25A/32A Mono 0 580 13 + 0 590 53	0 580 13 + 0 590 54	
Mode 2 & 3	11/17/ 22 kW	1	1	2	-	16A	16/25/ 32 A Tri 0 580 14 + 0 590 53	0 580 14 + 0 590 54	
Mode 2 & 3	11/17/ 22 kW	2	2	2	-	16A	16/25/ 32 A Tri 0 580 15 + 0 590 53	0 580 15 + 0 590 54	
Mode 2 & 3	3.7 kW 4.6 kW	1	1	-	2	16A	16A/20A Mono 0 580 41 + 0 590 53	0 580 41 + 0 590 54	
Mode 2 & 3	3.7 kW 4.6 kW	2	2	-	2	16A	16A/20A Mono 0 580 42 + 0 590 53	0 580 42 + 0 590 54	
Mode 2 & 3	5.7 kW 7.4 kW	1	1	-	2	16A	25A/32A Mono 0 580 43 + 0 590 53	0 580 43 + 0 590 54	
Mode 2 & 3	5.7 kW 7.4 kW	2	2	-	2	16A	25A/32A Mono 0 580 44 + 0 590 53	0 580 44 + 0 590 54	
Mode 2 & 3	11/17/ 22 kW	1	1	-	2	16A	16/25/ 32 A Tri 0 580 48 + 0 590 53	0 580 48 + 0 590 54	
Mode 2 & 3	11/17/ 22 kW	2	2	-	2	16A	16/25/ 32 A Tri 0 580 49 + 0 590 53	0 580 49 + 0 590 54	



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 263 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*
Julien GAUTHIER
Certification Officer

Date: 26/05/2023