



## Certificate of Conformity

LOVAG-Certificate No.: IT 18.138 Page 1 of 2

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as a member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Verification instruction wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the LOVAG Signatory responsible for this Certificate



ACCREDI*A* PRD N°070B Signatory of EA, IAF and ILAC Mutual Recognition Agreements

Apparatus: Low-voltage assembly  $415 \text{ V} (U_n) - 690 \text{ V} (U_i) - 6 \text{ kV} (U_{imp}) - 50/60 \text{ Hz} (f) - 630 \text{ A} (I_{nA}) - 36 \text{ kA} (I_{cc})$ - 36 kA (I<sub>cw</sub>) x 0,5 s (t) - IP40 - IK08

**Designation Type** 

XL3 S 630 Arrangement 147

Manufacturer Legrand SA

128, Avenue du Marechal du Lattre de Tassigny 87045 Limoges Cedex - France

Applicant:

Legrand SA

128, Avenue du Marechal du Lattre de Tassigny

87045 Limoges Cedex - France

Verified by:

**ACAE Laboratory:** IB01 Varese (Italy)

The apparatus, constructed in accordance with the description mentioned in the Report listed in this Certificate has been subjected to the series of proving verifications in accordance with

IEC 61439-2 Ed.2.0 (2011-08) and EN 61439-2 (2011-10):

- 10.2.2	Resistance to corrosion
1005	1.100

- 10.2.5 Lifting

- 10.2.6 Mechanical impact

- 10.4 Clearance and creepage distances

- 10.5 Protection against electrical shock and integrity of the protective circuit

- 10.6 Incorporation of switching devices and components

-10.7Internal electrical circuits and connections

- 10.8 Terminals for external conductors

- 10.9 Dielectric proprerties

- 10.10.2.3.5 Temperature rise

- 10.11 Short circuit withstand strength

-10.13Mechanical operation

The results are shown in the Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated at pages no. 2

> Responsible Certification Body: ACAE Via Tito Livio, 5 – 24123 – BERGAMO (Italy)

> > Authorized Signature: Virginio Scarioni Date: 2018.12.17

MOD 007 pag 1 Revisione 0





## Certificate

## of Conformity

LOVAG-Certificate No.: IT 18.138

Page 2 of 2

Circuit		Incoming	Horizontal	Functional Units		
	Circuit	vert. busbar	busbar	CC5 415	CC6 415	D1 415
Rated operat	ional voltage (U <sub>e</sub> ) V	415	415			
Rated insulation voltage (Ui) V		690	690	690	690	690
Loading	Rated current (Inc) A	630	176	280	175	176
condition 1	Rated diversity factor	1	1	1	1	1
Loading condition 2	Rated current (Inc) A	630	515	0	115	515
	Rated diversity factor	1	1	1	1	1
Rated short-time withstand current (I <sub>cw</sub> ) kA – (t) s		36 – 0,5	36 – 0,5	-	-	N=2
Rated peak withstand current (Ipk) kA		75,6	75,6	-	-	( <del>-</del>
Rated conditional short-circuit current (I <sub>cc</sub> ) kA		36	36	36	36	36

Circuit  Rated operational voltage (U <sub>e</sub> ) V  Rated insulation voltage (U <sub>i</sub> ) V		Functional Units						
		D2	D3	CC3	CC4	CC1	CC2	
		415 690	415 690	415 690	415 690	415 690	415 690	
								Loading condition 1
Rated diversity factor	(1 <del>4</del> )	-	1	1	_	( e)		
Loading condition 2	Rated current (Inc) A	117	176	0	112	55	55	
	Rated diversity factor	1	1	-	1	1	1	
Rated short-time withstand current (I <sub>ow</sub> ) kA - (t) s		ne.	-	-	(96)	-	-	
Rated peak withstand current (Ipk) kA		)( <del>=</del> )	-	-		-	() <del>*</del> ).	
Rated conditional short-circuit current (I <sub>cc</sub> ) kA		36	36	36	36	36	36	



This document includes: Assessment report No. 1555

Issue date: 2018.11.07 Test report No. 1169 Issue date: 2017.09.20 Test report No. 1255 Issue date: 2018.01.05 Test report No. 1484 Issue date: 2018.07.25 Test report No. 1528 Issue date: 2018.10.16

> Responsible Certification Body: ACAE Via Tito Livio, 5 – 24123 + BERGAMO (Italy)



Authorized Signature: Virginio Scarioni

Date: 2018.12.17