



Attestation of Conformity

ISO/IEC, EN & TIA Unscreened Class E_A / Category 6A Two Connector Permanent Link

Legrand
128 Avenue de Lattre de Tassigny
F-87045 Limoges Cedex, France

Attestation of Conformity No. 1171012

This type of Class E_A / Category 6A unscreened two connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E_A requirements of edition 2.2 of ISO/IEC 11801 and CENELEC EN 50173-1:2011, and Category 6A requirements of ANSI/TIA-568-C.2. The Attestation of Conformity is only valid for the actually tested permanent link type in T568B designation connected with RJ 45 plugs from Legrand patch cords P/N 51874 / 75 / 76 / 77 or P/N 51878 / 79 / 80 / 81 and consisting of the following Legrand components:

<i>Cables:</i>	<i>Horizontal Cable,</i>	<i>P/N 32787</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Patch Panel,</i>	<i>P/N HD61</i>
	<i>Wall Outlet,</i>	<i>P/N SA61</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 20th December 2017

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 20th December 2017

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen".

Jens Rytter Petersen
General Manager