



Preventa safety modules

XPSAK

For Emergency stop, switch,
sensing mat/edges
or safety light curtain monitoring

Catalogue



june 2014



Preventa safety modules

Type XPSAK

For Emergency stop, switch, sensing mat/edges or safety light curtain monitoring



Operating principle

Safety modules **XPSAK** meet the requirements of Performance Level PL e/Category 4 conforming to standard EN/ISO 13849-1.

They are used for:

- Monitoring Emergency stop circuits conforming to standards EN/ISO 13850 and EN/IEC 60204-1.
- Electrical monitoring of switches activated by protection devices, with optional selection of synchronisation time between signals.
- Monitoring 4-wire sensing mats or edges.
- Monitoring type 4 light curtains conforming to EN/IEC 61496-1 which have solid-state safety outputs with test function (light curtains XUSL).
- Housed in a compact enclosure, the modules have 3 safety outputs, a relay signalling output and 4 solid-state signalling outputs for signalling to the process PLC.
- Preventa safety modules **XPSAK●●●●P** incorporate removable terminal blocks, thus optimising machine maintenance.
- To aid diagnostics, the modules have 4 LEDs on the front face which provide information on the monitoring circuit status.
- The Start button monitoring function is configurable depending on the wiring.

Maximum achievable safety level

- PL e/Category 4 conforming to EN/ISO 13849-1,
- SILCL3 conforming to EN/IEC 61508 and EN/IEC 62061

Product certifications

- UL
- CSA
- TÜV

References

Description	Connection	Number of safety circuits	Additional outputs / Solid-state outputs for PLC	Supply	Reference	Weight kg/ lb	
Safety modules for Emergency stop, switch, sensing mat/edges or safety light curtain monitoring	Captive screw clamp terminals Terminal block integrated in module	3	1 / 4	~ and --- 24 V	XPSAK311144	0.300/ 0.661	
				~ 110 V --- 24 V	XPSAK361144	0.400/ 0.882	
				~ 120 V --- 24 V	XPSAK351144	0.400/ 0.882	
				~ 230 V --- 24 V	XPSAK371144	0.400/ 0.882	
	Captive screw clamp terminals Terminal block removable from module	3	1 / 4		~ and --- 24 V	XPSAK311144P	0.300/ 0.661
					~ 48 V	XPSAK331144P	0.300/ 0.661
					~ 110 V --- 24 V	XPSAK361144P	0.400/ 0.882
					~ 120 V --- 24 V	XPSAK351144P	0.400/ 0.882
				~ 230 V --- 24 V	XPSAK371144P	0.400/ 0.882	




XPSAK31144

Preventa safety modules

Type XPSAK

For Emergency stop, switch, sensing mat/edges or safety light curtain monitoring

>> Wiring diagram and Functional Diagram are available on the “e-Shop” via the partnumber.



Operating principle, references

Preventa safety modules

Type XPSAK
For Emergency stop, switch, sensing mat/edges or safety light curtain monitoring

Operating principle

Safety modules **XPSAK** meet the requirements of Performance Level PL e/Category 4 conforming to standard EN/ISO 13849-1. They are used for:

- Monitoring Emergency stop circuits conforming to standards EN/ISO 13850 and EN/IEC 60204-1.
- Electrical monitoring of switches activated by protection devices, with optional selection of synchronisation time between signals.
- Monitoring 4-wire sensing mats or edges.
- Monitoring type 4 light curtains conforming to EN/IEC 61496-1 which have solid-state safety outputs with test function (light curtains XUSL).
- Housed in a compact enclosure, the modules have 3 safety outputs, a relay signalling output and 4 solid-state signalling outputs for signalling to the process PLC.
- Preventa safety modules **XPSAK****P** incorporate removable terminal blocks, thus optimising machine maintenance.
- To aid diagnostics, the modules have 4 LEDs on the front face which provide information on the monitoring circuit status.
- The Start button monitoring function is configurable depending on the wiring.

Maximum achievable safety level

- PL e/Category 4 conforming to EN/ISO 13849-1, EN/IEC 61508 and EN/IEC 62061

References

Description	Connection	Number of safety circuits	Additional outputs / Solid-state outputs for PLC	Supply	Reference	Weight kg/lb
Safety modules for Emergency stop, switch, sensing mat/edges or safety light curtain monitoring	Captive screw clamp terminals Terminal block integrated in module	3	1/4	~ and 24 V ~ 110 V ~ 24 V	XPSAK311144 XPSAK311144	0.300/ 0.661 0.400/ 0.882

> Click on a partnumber, the hyperlink opens the “e-Shop”

> Click on “Documents & Download”

XPSAK311144
module XPSAK - Emergency stop - 24 V AC DC

Download your XPSAK311144 datasheet

Change your selection - Remove all

Safety module application: For emergency stop, switch, sensing mat/edges or safety light curtain monitoring

Output type: Relay instantaneous opening 3 NO, volt-free

[Us] rated supply voltage: 24 V AC (-15...10 %)

Connections - terminals: Captive screw clamp terminals, damping capacity: 2 x 0.5 - 2 x 1.5 mm² flexible cable with cable end, with double bezel

Number of additional circuits: 1 NC + 4 solid state outputs

Characteristics | Dimensions Drawings | Connections and Schema | Documents & Downloads

Main

Complementary

Environment

> Click on “Instruction sheet”

Schneider Electric

Discover your Schneider Electric tools | Add to favorites | Help | Historic

Top - 24 V AC DC

Refine your selection

- Product image
- Instruction sheet
- User guide
- Product environmental
- End of life manual
- Certificate

Result: 3 documents

Product image

Security module for emergency stop surveillance
4/10/2013 4:51:12 AM
(Select your format)

Instruction sheet

XPSAK Safety module for Emergency stop, switch, sensing mat/edges or safety light curtain monitoring
(Select your format)



More information on
<http://www.schneider-electric.com/machinesafety>

Schneider Electric Industries SAS

Head Office
35, rue Joseph Monier
F-92500 Rueil-Malmaison
France

The information provided in this documentation contains general descriptions and/or technical characteristics of the performance of the products contained herein. This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications. It is the duty of any such user or integrator to perform the appropriate and complete risk analysis, evaluation and testing of the products with respect to the relevant specific application or use thereof. Neither Schneider Electric nor any of its affiliates or subsidiaries shall be responsible or liable for misuse of the information contained herein.

Design: Schneider Electric
Photos: Schneider Electric