

UK DECLARATION OF CONFORMITY

We: MANUFACTURER
Schneider Electric Industries SAS
35 rue Joseph Monier
Rueil Malmaison 92500 – France

UK REPRESENTATIVE Schneider Electric Limited Stafford Park 5 Telford, TF3 3BL - United Kingdom

Trademark	Schneider Electric	
Product, Type	IM9 & IM9-OL	
	Insulation Monitoring Devices	
List of reference and options	Refer Annex 1	

Are in conformity with the requirements of the following regulation and conformity was checked in accordance with the following standards.

Regulation	Designated standard / Notified body reference		
Electrical Equipment (Safety) Regulations	BS EN 61010-1:2010		
SI 2016 No. 1101	BS EN 61557-8:2015		
The Electromagnetic Compatibility Regulations SI 2016 No. 1091	BS EN IEC 61326-2-4:2013		
The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 SI 2012 No. 3032	BS EN IEC 63000:2018		

Subject to correct installation, maintenance and use conforming to its intended purpose, to the applicable regulations and standards, to the supplier's instructions and to accepted rules of the art.

This declaration becomes invalid in the case of any modification to the products not authorized by us.

Person in charge of the documentation (Manufacturer): Kumudha V

#12A, Attibele Industrial Area Hosur Main Road Neralur Post, Bangalore 562107 India

Issued at Telford - United Kingdom (Representative): Date & Signature 11-July-2022

DocuSigned by:

David Williams

Name: David WILLIAMS
VP Marketing UK&I
Zone UK & Ireland



UK DECLARATION OF CONFORMITY



IMD-IM9-OL: Insulation Monitoring Device for Off-Line equipment (motors). It measures the insulation resistance between the stator and ground

IMD-IM9: Insulation monitoring device for low voltage, AC IT power systems

Annex 1: Applied Designated British Standards

Commercial name(s)	Commercial reference(s)	UKCA marking application date	Applicable standards
IM9	IMD-IM9	2022	 As an insulation monitoring device: BS EN 61010-1:2010 BS EN 61557-8:2015 BS EN 61326-2-4:2013
IM9-OL	IMD-IM9-OL		BS EN IEC 63000:2018