



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-167-16**

Valid from: 2023 07 07  
until: 2025 07 07

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

Product: **Appliance inlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3722-1862/23**

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*M. Neugebauer*  
Digitally signed by M. Neugebauer  
on behalf of T. Neumayer  
Email=m.neugebauer@ove.at  
Dipl.-Ing. T. Neumayer



Wien, 2023 06 28

## OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



**Manufacturer:**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Factory location(s):**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Tested and certified according to:**

ÖVE/ÖNORM EN 60309-1:2013-03-01  
OVE EN IEC 60309-1:2023-07-01  
ÖVE/ÖNORM EN 60309-2:2013-03-01  
OVE EN IEC 60309-2:2023-07-01  
IEC 60309-1:2021  
IEC 60309-2:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Appliance inlets for industrial purposes**

**Type designation:**

**Rating:**

**Trademark:**

**533**

Rated current: 63 A  
2P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**633**

Rated current: 63 A  
2P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**733**

Rated current: 63 A  
2P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**77733**

Rated current: 63 A  
2P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**534**

Rated current: 63 A  
3P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**634**

Rated current: 63 A  
3P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**734**

Rated current: 63 A  
3P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**77734**

Rated current: 63 A  
3P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**535**

Rated current: 63 A  
3P+N+PE  
IP 67 or IP 66/IP 67  
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**635**

Rated current: 63 A  
3P+N+PE  
IP 67 or IP 66/IP 67  
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**735**

Rated current: 63 A  
3P+N+PE  
IP 67 or IP 66/IP 67  
with pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**77735**

Rated current: 63 A  
3P+N+PE  
IP 67 or IP 66/IP 67  
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**5332**

Rated current: 63 A  
2P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**6332**

Rated current: 63 A  
2P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**7332**

Rated current: 63 A  
2P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**777332**

Rated current: 63 A  
2P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**5342**

Rated current: 63 A  
3P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**6342**

Rated current: 63 A  
3P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**7342**

Rated current: 63 A  
3P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**777342**

Rated current: 63 A  
3P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**5352**

Rated current: 63 A  
3P+N+PE  
IP 67 or IP 66/IP 67  
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**6352**

Rated current: 63 A  
3P+N+PE  
IP 67 or IP 66/IP 67  
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**7352**

Rated current: 63 A  
3P+N+PE  
IP 67 or IP 66/IP 67  
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**777352**

Rated current: 63 A  
3P+N+PE  
IP 67 or IP 66/IP 67  
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**5331**

Rated current: 63 A  
2P+PE  
IP 44  
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**53321**

Rated current: 63 A  
2P+PE  
IP 44  
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**5341**

Rated current: 63 A  
3P+PE  
IP 44  
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**53421**

Rated current: 63 A  
3P+PE  
IP 44  
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**5351**

Rated current: 63 A  
3P+N+PE  
IP 44  
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**53521**

Rated current: 63 A  
3P+N+PE  
IP 44  
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**6331**

Rated current: 63 A  
2P+PE  
IP 44  
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**63321**

Rated current: 63 A  
2P+PE  
IP 44  
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**6341**

Rated current: 63 A  
3P+PE  
IP 44  
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**63421**

Rated current: 63 A  
3P+PE  
IP 44  
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**6351**

Rated current: 63 A  
3P+N+PE  
IP 44  
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**63521**

Rated current: 63 A  
3P+N+PE  
IP 44  
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**777331**

Rated current: 63 A  
2P+PE  
IP 44  
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**7773321**

Rated current: 63 A  
2P+PE  
IP 44  
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**777341**

Rated current: 63 A  
3P+PE  
IP 44  
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**7773421**

Rated current: 63 A  
3P+PE  
IP 44  
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**777351**

Rated current: 63 A  
3P+N+PE  
IP 44  
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

**7773521**

Rated current: 63 A  
3P+N+PE  
IP 44  
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

---

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

777	3	5	2	1	-	6	k	*	b
-----	---	---	---	---	---	---	---	---	---

<b>Contacts</b>	
blank	nickel plated contacts
b	uncoated contacts
<b>Colour</b>	
blank	standard type
xs	Midnight series
*	reserved for additional colours
<b>Specification</b>	
blank	standard type
k	version with compact housing (for types of series 6 and 777)
<b>Clock position earthing contact</b>	
1	1 h
2	2 h
3	3 h
4	4 h
5	5 h
6	6 h
7	7 h
8	8 h (not available in 4- and 5-poles)
9	9 h
10	10 h
11	11 h
12	12 h
<b>Customer type</b>	
-	Trademark PCE
<b>Degree of protection</b>	
blank	IP67 or IP66/IP67
1	IP44
<b>Pilot contact</b>	
blank	with pilot contact
2	without pilot contact
<b>Poles</b>	
3	3-poles
4	4-poles
5	5-poles
<b>Rated current</b>	
3	63A
<b>Ground type</b>	
777	Flanged plug
5	Wall mounted plug
6	Flanged plug straight
7	Flanged plug sloping

## OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

### Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
533 633 733 77733  5332 6332 7332 777332	63	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	>50 - 250	DC	690
		4	100 - 130	50 and 60	690
		6	200 - 250	50 and 60	690
		7	480 - 500	50 and 60	690
		8	>250	DC	690
		9	380 - 415	50 and 60	690
		10	>50	>100 - 300	690
		12	Supply from an isolating transformer	50 and 60	690
534 634 734 77734  5342 6342 7342 777342	63	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	380 440	50 60	690
		4	100 - 130	50 and 60	690
		5	600 - 690	50 and 60	690
		6	380 - 415	50 and 60	690
		7	480 - 500	50 and 60	690
		9	200 - 250	50 and 60	690
		10	>50	>100 - 300	690
		11	440 - 460	60	690
12	Supply from an isolating transformer	50 and 60	690		
535 635 735 77735  5352 6352 7352 777352	63	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	220/380 250/440	50 60	690
		4	57/100 - 75/130	50 and 60	690
		5	347/600 - 400/690	50 and 60	690
		6	200/346 - 240/415	50 and 60	690
		7	277/480 - 288/500	50 and 60	690
		9	120/208 - 144/250	50 and 60	690
		10	>50	>100 - 300	690
		11	250/440 - 265/460	60	690
12	Supply from an isolating transformer	50 and 60	690		

#### OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

## Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V		
5331 6331 777331  53321 63321 7773321	63	1	Other ratings	Other ratings	690		
		2	>50	>300 - 500	690		
		3	>50 - 250	DC	690		
		4	100 - 130	50 and 60	690		
		6	200 - 250	50 and 60	690		
		7	480 - 500	50 and 60	690		
		8	>250	DC	690		
		9	380 - 415	50 and 60	690		
		10	>50	>100 - 300	690		
		12	Supply from an isolating transformer	50 and 60	690		
5341 6341 777341  53421 63421 7773421	63	1	Other ratings	Other ratings	690		
		2	>50	>300 - 500	690		
		3	380 440	50 60	690		
		4	100 - 130	50 and 60	690		
		5	600 - 690	50 and 60	690		
		6	380 - 415	50 and 60	690		
		7	480 - 500	50 and 60	690		
		9	200 - 250	50 and 60	690		
		10	>50	>100 - 300	690		
		11	440 - 460	60	690		
				12	Supply from an isolating transformer	50 and 60	690
		5351 6351 777351  53521 63521 7773521	63	1	Other ratings	Other ratings	690
2	>50			>300 - 500	690		
3	220/380 250/440			50 60	690		
4	57/100 - 75/130			50 and 60	690		
5	347/600 - 400/690			50 and 60	690		
6	200/346 - 240/415			50 and 60	690		
7	277/480 - 288/500			50 and 60	690		
9	120/208 - 144/250			50 and 60	690		
10	>50			>100 - 300	690		
11	250/440 - 265/460			60	690		
				12	Supply from an isolating transformer	50 and 60	690

### Accessories:

ts7632 •

┌───┐ ├───┤ └───┘	<b>colour</b>	
	g	- grey
	*	- reserved for additional colours

**Water protection cap IP67 or IP66/67**

### OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.