



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-168-13**

Valid from: 2021 07 07  
until: 2023 07 07

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

Product: **Appliance inlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 37226**

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*T. Neumayer*

Digitally signed by T. Neumayer  
Email=[t.neumayer@ove.at](mailto:t.neumayer@ove.at)

Dipl.-Ing. T. Neumayer

Wien, 2021 06 17



## OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).



**Manufacturer:**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Factory location(s):**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Tested and certified according to:**

ÖVE/ÖNORM EN 60309-1:2013-03-01  
ÖVE/ÖNORM EN 60309-2:2013-03-01  
IEC 60309-1:1999 + A1:2005 + A2:2012  
IEC 60309-2:1999 + A1:2005 + A2:2012

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Appliance inlets for industrial purposes**

**Type designation:**

*Rating:*

**Trademark:**

**543**

Rated current: 125 A  
Insulation voltage: 690 V  
2P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**643**

Rated current: 125 A  
Insulation voltage: 690 V  
2P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).

**743**

Rated current: 125 A  
Insulation voltage: 690 V  
2P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**544**

Rated current: 125 A  
Insulation voltage: 690 V  
3P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**644**

Rated current: 125 A  
Insulation voltage: 690 V  
2P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**744**

Rated current: 125 A  
Insulation voltage: 690 V  
2P+PE  
IP 67 or IP 66/IP 67  
with pilot contact, appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**545**

Rated current: 125 A  
Insulation voltage: 690 V  
3P+N+PE  
IP 67 or IP 66/IP 67  
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**645**

Rated current: 125 A  
Insulation voltage: 690 V  
3P+N+PE  
IP 67 or IP 66/IP 67  
with pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**745**

Rated current: 125 A  
Insulation voltage: 690 V  
3P+N+PE  
IP 67 or IP 66/IP 67  
with pilot contact, appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).

**5432**

Rated current: 125 A  
Insulation voltage: 690 V  
2P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**6432**

Rated current: 125 A  
Insulation voltage: 690 V  
2P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**7432**

Rated current: 125 A  
Insulation voltage: 690 V  
2P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**5442**

Rated current: 125 A  
Insulation voltage: 690 V  
3P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**6442**

Rated current: 125 A  
Insulation voltage: 690 V  
3P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**7442**

Rated current: 125 A  
Insulation voltage: 690 V  
3P+PE  
IP 67 or IP 66/IP 67  
without pilot contact, appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

**5452**

Rated current: 125 A  
Insulation voltage: 690 V  
3P+N+PE  
IP 67 or IP 66/IP 67  
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).

**6452**

Rated current: 125 A

Insulation voltage: 690 V

3P+N+PE

IP 67 or IP 66/IP 67

without pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

**7452**

Rated current: 125 A

Insulation voltage: 690 V

3P+N+PE

IP 67 or IP 66/IP 67

without pilot contact, appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

---

**OVE Certification**


Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).

### Typlist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz
543 5432 643 6432 743 7432	125	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	>50 - 250	DC
		4	100 – 130	50 and 60
		6	200 – 250	50 and 60
		7	480 – 500	50 and 60
		8	>250	DC
		9	380 – 415	50 and 60
		10	>50	>100 - 300
		12	Supply from an isolating transformer	50 and 60
544 5442 644 6442 744 7442	125	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	380 440	50 60
		4	100 – 130	50 and 60
		5	600 – 690	50 and 60
		6	380 – 415	50 and 60
		7	480 - 500	50 and 60
		9	200 – 250	50 and 60
		10	>50	>100 - 300
		11	440 – 460	60
		12	Supply from an isolating transformer	50 and 60
		545 5452 645 6452 745 7452	125	1
2	>50			>300 - 500
3	220/380 250/440			50 60
4	57/100 – 75/130			50 and 60
5	347/600 – 400/690			50 and 60
6	200/346 – 240/415			50 and 60
7	277/480 – 288/500			50 and 60
9	120/208 – 144/250			50 and 60
10	>50			>100 - 300
11	250/440 – 265/460			60
12	Supply from an isolating transformer			50 and 60

#### Additional component:

ts1252 •



#### OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).