



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-217-05**

Valid from: 2022 03 14
until: 2024 03 14

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Switched socket-outlets for industrial purpose**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 37287**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2022 02 03



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
ÖVE/ÖNORM EN 60309-4:2012-12-01
IEC 60309-1:1999 + A1:2005 + A2:2012
IEC 60309-2:1999 + A1:2005 + A2:2012
IEC 60309-4:2006 + A1:2012

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Switched socket-outlets for industrial purpose

Type designation:

Rating:

Trademark:

7513

Rated current: 16 A
2P+E
IP44 or IP44/IP54
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

7613

Rated current: 16 A
2P+E
IP44 or IP44/IP54
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

7813

Rated current: 16 A
2P+E
IP44 or IP44/IP54
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

75132

Rated current: 16 A
2P+E
IP67 or IP66/IP67
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

76132

Rated current: 16 A
2P+E
IP67 or IP66/IP67
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

78132

Rated current: 16 A
2P+E
IP67 or IP66/IP67
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

7514

Rated current: 16 A
3P+E
IP44 or IP44/IP54
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

7614

Rated current: 16 A
3P+E
IP44 or IP44/IP54
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

7814

Rated current: 16 A
3P+E
IP44 or IP44/IP54
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

75142

Rated current: 16 A
3P+E
IP67 or IP66/IP67
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

76142

Rated current: 16 A
3P+E
IP67 or IP66/IP67
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

78142

Rated current: 16 A
3P+E
IP67 or IP66/IP67
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

7515

Rated current: 16 A
3P+N+E
IP44 or IP44/IP54
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

7615

Rated current: 16 A
3P+N+E
IP44 or IP44/IP54
Screw terminals
with switch and DIN-rail
see type list

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

7815

Rated current: 16 A
3P+N+E
IP44 or IP44/IP54
Screw terminals
with switch and fuse
see type list

PCE / ELCEE / SIROX / METECEE

75152

Rated current: 16 A
3P+N+E
IP67 or IP66/IP67
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

76152

Rated current: 16 A
3P+N+E
IP67 or IP66/IP67
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

78152

Rated current: 16 A
3P+N+E
IP67 or IP66/IP67
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
7513 7613 7813 75132 76132 78132	16	1	Other ratings	Other ratings	690*)/500**)/415***)
		4	100 – 130	50 and 60	
		6	200 – 250	50 and 60	
		7	480 – 500	50 and 60	
		9	380 – 415	50 and 60	
		12	Supply from an isolating transformer	50 and 60	
7514 7614 7814 75142 76142 78142	16	1	Other ratings	Other ratings	
		3	380 440	50 60	
		4	100 – 130	50 and 60	
		5	600 – 690	50 and 60	
		6	380 – 415	50 and 60	
		7	480 - 500	50 and 60	
		9	200 – 250	50 and 60	
		11	440 – 460	60	
		12	Supply from an isolating transformer	50 and 60	
7515 7615 7815 75152 76152 78152	16	1	Other ratings	Other ratings	
		3	220/380 250/440	50 60	
		4	57/100 – 75/130	50 and 60	
		5	347/600 – 400/690	50 and 60	
		6	200/346 – 240/415	50 and 60	
		7	277/480 – 288/500	50 and 60	
		9	120/208 – 144/250	50 and 60	
		11	250/440 – 265/460	60	
		12	Supply from an isolating transformer	50 and 60	

*) Series 75... und 76... - Insulation voltage 690 V

***) Series 78... with fuse (Diazed) - Insulation voltage 500 V

***) Series 78... with fuse (Noezed) - Insulation voltage 415 V

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.