



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-214-05**

Valid from: 2022 02 17
until: 2024 02 17

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Switched socket-outlets for industrial purpose**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 37288**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at



Wien, 2022 01 18

Dipl.-Ing. T. Neumayer

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
ÖVE/ÖNORM EN 60309-4:2012-12-01
IEC 60309-1:1999 + A1:2005 + A2:2012
IEC 60309-2:1999 + A1:2005 + A2:2012
IEC 60309-4:2006 + A1:2012

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Switched socket-outlets for industrial purpose

Type designation:

Rating:

Trademark:

7523

Rated current: 32 A
2P+E
IP44 or IP44/IP54
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

7623

Rated current: 32 A
2P+E
IP44 or IP44/IP54
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

7823

Rated current: 32 A
2P+E
IP44 or IP44/IP54
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

75232

Rated current: 32 A
2P+E
IP67 or IP66/IP67
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

76232

Rated current: 32 A
2P+E
IP67 or IP66/IP67
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

78232

Rated current: 32 A
2P+E
IP67 or IP66/IP67
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

7524

Rated current: 32 A
3P+E
IP44 or IP44/IP54
Screw terminals

PCE / ELCEE / SIROX / METECEE

with switch
see typelist

7624

Rated current: 32 A
3P+E
IP44 or IP44/IP54
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

7824

Rated current: 32 A
3P+E
IP44 or IP44/IP54
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

75242

Rated current: 32 A
3P+E
IP67 or IP66/IP67
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

76242

Rated current: 32 A
3P+E
IP67 or IP66/IP67
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

78242

Rated current: 32 A
3P+E
IP67 or IP66/IP67
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

7525

Rated current: 32 A
3P+N+E
IP44 or IP44/IP54
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

7625

Rated current: 32 A
3P+N+E
IP44 or IP44/IP54
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

7825

Rated current: 32 A
3P+N+E
IP44 or IP44/IP54
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

75252

Rated current: 32 A
3P+N+E
IP67 or IP66/IP67
Screw terminals
with switch
see typelist

PCE / ELCEE / SIROX / METECEE

76252

Rated current: 32 A
3P+N+E
IP67 or IP66/IP67
Screw terminals
with switch and DIN-rail
see typelist

PCE / ELCEE / SIROX / METECEE

78252

Rated current: 32 A
3P+N+E
IP67 or IP66/IP67
Screw terminals
with switch and fuse
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
7523 7623 7823 75232 76232 78232	32	1	Other ratings	Other ratings	690*)/500**)/415***)
		4	100 – 130	50 and 60	
		6	200 – 250	50 and 60	
		7	480 – 500	50 and 60	
		9	380 – 415	50 and 60	
		12	Supply from an isolating transformer	50 and 60	
7524 7624 7824 75242 76242 78242	32	1	Other ratings	Other ratings	
		3	380 440	50 60	
		4	100 – 130	50 and 60	
		5	600 – 690	50 and 60	
		6	380 – 415	50 and 60	
		7	480 - 500	50 and 60	
		9	200 – 250	50 and 60	
		11	440 – 460	60	
		12	Supply from an isolating transformer	50 and 60	
7525 7625 7825 75252 76252 78252	32	1	Other ratings	Other ratings	
		3	220/380 250/440	50 60	
		4	57/100 – 75/130	50 and 60	
		5	347/600 – 400/690	50 and 60	
		6	200/346 – 240/415	50 and 60	
		7	277/480 – 288/500	50 and 60	
		9	120/208 – 144/250	50 and 60	
		11	250/440 – 265/460	60	
		12	Supply from an isolating transformer	50 and 60	

*) Series 75... and 76... - Insulation voltage 690 V

**) Series 78... with fuse (Diazed) - Insulation voltage 500 V

***) Series 78... with fuse (Noezed) - Insulation voltage 415 V

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.