THRESHOLD MONITORING FOR CURRENT SIGNAL




- Input: 0...40 A AC
- Output: SPDT contact
- Insulation: 3.0 kVac, 2-way isolation
- · Adjustable threshold value

NOTE

(1) The relay is turned on and the transistor output is "high" with input signal under the threshold value

[2] The insulation refers to an uninsulated conductor in contact with the toroid wall. Using insulated conductors, the insulation value of the conductor is added to the isolation value of the converter



	(B)	
CODE	XC	CIS2
ТҮРЕ	CCIS-2	
INPUT TECHNICAL DATA		
Signal type IN	analogue	
Input range IN	40 A (AC 5060 Hz)	
Maximum voltage current signal IN	600 Vac / 50 A [1]	
Input impedance IN	-	
Hysteresis	_	
Parametrization IN	-	
OUTPUT TECHNICAL DATA		
Signal type OUT	SPDT contact , PNP open collector transistor (1)	
Output range OUT	100 mA (PNP open collector)	
Status indication OUT	LED	
Operating mode OUT	limit value	
Parametrization OUT	240 A ± 10% (trimmer)	
GENERAL TECHNICAL DATA		
Power supply voltage	24 Vdc ± 10%	
Current consumption	100 mA	
Auxiliary output voltage	_	
Accuracy	-	
Linearity error	_	
Temperature coefficient	-	
Setting time	20 ms	
Transmission frequency	_	
Resolution	_	
Rise time	-	
Operating temperature range	-20+60°C	
Insulation	3.0 kVac / 60 s (2)	
Insulation type	2-way (IN / OUT)	
Standard approvals	-	
EMC Standards		
Overvoltage category / Pollution degree	IP 00	
Protection degree Connection terminal IN / OUT		
Housing material	cable, through in a 13 mm Ø hole / 2.5 mm² (screw) UL94V-0 plastic material	
Dimensions	50x93x70 mm	
Approximate weight	100 q	
Mounting information	vertical on a rail, distance 5 mm from adjacent components	
-		
APPROVALS		
ACCESSORIES		
Mounting rail (IEC60715/TH35-7.5)	PR/3/AC, PR/3/AC/ZB, PR/3/AS, PR/3/AS/ZB	
Mounting rail (IEC60715/TH35-15)	PR/3/PP, PR/3/PP/ZB, PR/3/PA, PR/3/PA/ZB	
Marking tag	_	
Plugin jumper red	-	
Plugin jumper white	_	
Plugin jumper blue	-	
Programming kit	<u> </u>	

APPLICATIONS

Inserted into a current circuit, the module can be used to set (using a precision potentiometer) the desired current value for the relay or transistor switch, obtaining a current threshold above or below which the switch occurs. The cable carrying the current must be passed through the module's toroidal sensor. The relay or the transistor switches when the set current threshold is surpassed.

- (A) AC Load
- (B) Control threshold
- (C) Exchange output contact
- (D) Transistor-controlled digital input 24 Vac/dc power supply