

IEC

IECEE

Ref. Certif. No.

FR_706894/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Boxes and enclosures
Boxes and enclosures for electrical accessories

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

LEGRAND

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Serie BATIBOX / multi-material
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_706894 dated 24/09/2019. Addition of product references and factory, change address of factory

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60670-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

23188876-803657

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 17/10/2024



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre 4408 263 114
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature:
Julien GAUTHIER
Certification Officer

IEC

IECEE

Ref. Certif. No.

FR_706894/M1

ANNEX

Name and address of the factories:

LEGRAND FRANCE

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

ERP ELBROMPLAST

STRADA SIEMENS NR 3
300704 TIMISOARA
ROMANIA

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT


IPARTELEPI UT 14 PF 10
6600 SZENTES
HUNGARY



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 17/10/2024



Signature: *Julien Gauthier*
Julien GAUTHIER
Certification Officer

ANNEX
RÉFÉRENCES - CARACTÉRISTIQUES PRINCIPALES / REFERENCES - MAIN CHARACTERISTICS

Reference	Capacity		Depth (mm)	Dimension (mm)	distance between centres (mm)
	gang	modules			
0 801 01	1	-	40	Φ 67	-
0 801 15	1	-	40	Φ 67	-
0 801 89	1	-	40	Φ 67	-
0 905 01	1	-	40	Φ 67	-
200 215	1	-	40	Φ 67	-
0 801 02	2	4/5	40	Φ 67	71
0 905 02	2	4/5	40	Φ 67	-
0 801 03	3	6/8	40	Φ 67	71
0 905 03	3	6/8	40	Φ 67	71
0 801 21	1	-	50	Φ 67	-
0 801 16	1	-	50	Φ 67	-
0 905 05	1	-	50	Φ 67	-
0 801 22	2	4/5	50	Φ 67	71
0 905 06	2	4/5	50	Φ 67	71
0 801 23	3	6/8	50	Φ 67	71
0 905 07	3	6/8	50	Φ 67	71
0 801 24	2x2	2x4/5	50	142 x 142	-
0 801 26	2x3	2x6/8	50	213 x 142	-
0 801 28	-	2x10	50	-	-
0 801 88	1	-	50	Φ 79	-

Classification

Rated insulation voltage	450V~
Nature of their material	Insulating
Method of installation	Flush in hollow walls , hollow ceilings , hollow floors or furniture
	Non-combustible walls, ceilings or floors
	Combustible walls, ceilings or floors
Type of inlets (outlets)	With inlets for plain or corrugated conduits
Clamping means	Without clamping means
Minimum and maximum temperatures during installation	-5°C to +60°C
Degree of protection of the part mounted inside the hollow walls	IP20
Arrangements to fix accessories to the boxes	Boxes supplied with screws


Accessories

Reference	Description
0 801 94	Rectangular lid for boxes 2x2 gangs
0 801 96	Rectangular lid for boxes 2x3 gangs
0 801 05	Device for molding and skirting board for Céliane range



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr



Signature: **Julien GAUTHIER**
Certification Officer

Date: 17/10/2024