



Ref. Certif. No.

FR_707532/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch for fixed electrical installation

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

MOSAIC series
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_707532 dated 24/12/2019. Addition of factory(ies), deletion of factory (ies), Addition of product references, Deletion of product references

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60669-1:2017


As shown in the Test Report Ref. No. which forms part of this Certificate

18932569-789601A, 18932569-789601B, 18092890-787009 ,
60037589-573268/1, 60037589-573268/2, 60051320-552307A,
60051320-552307B, 60051320-552333A/A1, 60051320-552333B,
80675-569874a, 80675-569867b,132235-666597B,
137906-677824A, 102524-603912 Cr 2012-05-15,102524-603915,
130899-663536Cr2016-10-05, 132235-666597A, 136898-675824A,
137906-677820, 137906-677824A, 144476-692817,
160795-735196B, 150730-709904B

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



Signature: Julien GAUTHIER
Certification Officer

Date: 05/07/2024

ANNEX**Name and address of the factories:****LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

LEGRAND FRANCE SILLE LE GUILLAUME

80 ROUTE D'EVRON
72140 SILLE LE GUILLAUME
FRANCE

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT

IPARTELEPI UT 14 PF 10
6600 SZENTES
HUNGARY

NP PLASTIC HUNGARIA

IPARI PARK 07/6
5440 KUNSZENMARTON
HUNGARY

PLASTIVALOIRE

ZI NORD
37130 LANGEAIS
FRANCE

BTICINO SPA

4 VIA LUCIANO MANARE
22036 ERBA
ITALY

NOVATEUR ELECTRICAL & DIGITAL SYSTEMS PVT. LTD

A-2, MIDC AREA, MALEGAON VILLAGE, SINNAR, DIST.
422113 NASHIK
MAHARASHTRA - INDIA

LACROIX ELECTRONICS TUNISIE

ZONE INDUSTRIELLE ZRIBA 2 - HAMMAM ZRIBA
1152 ZRIBA - ZAGHOUAN
TUNISIA

DONGGUAN ROCOM ELECTRIC COMPANY LIMITED

No. 5, Hong' An Road, Wu Sha District, Chang'an Town
523857 DONGGUAN
Guangsong - CHINA

MIO CONTO Kft.

ELEGE 72-76
6630 Mindszent
Csongrad - HUNGARY



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

LABORATOIRE CENTRAL DES

INDUSTRIES ELECTRIQUES

S.A.S au capital de 15.745.984 €

RCS Nanterre B 488 363 174

33 avenue du Général Leclerc

F - 92266 FONTENAY AUX ROSES

Julien Gauthier
Signature: **Julien GAUTHIER**
Certification Officer

Date: 05/07/2024

ANNEX


References, ratings and main characteristics:

Type reference	References	Pattern	Actuating	Terminals	Rating	Colour of actuating member	Number of modules
CM11	0 770 00L	1	R	slt	10AX / 250V	White with pilot light	1
CM21	0 770 10	1	R	slt	10AX / 250V	White	2
	0 770 10L	1	R	slt	10AX / 250V	White with pilot light	2
CM16	0 792 01	6	R	slt	10AX / 250V	Aluminium	1
CM16B	0 770 48	6 + 6	R + R	slt	10AX / 250V	White with pilot light	1 + 1
	0 770 01L	6	R	slt	10AX / 250V	White with pilot light	1
	0 994 00	6	R	slt	10AX / 250V	White with pilot light	1
	0 994 04	6	R	slt	10AX / 250V	White with pilot light	1
	0 992 11	6 + 6	R	slt	10AX / 250V	White with pilot light	1 + 1
	0 992 01	6 + 6	R	slt	10AX / 250V	White with pilot light	1 + 1
	0 994 02	6	R	slt	10AX / 250V	White with pilot light	1
	200 076	6	R	slt	10AX / 250V	White with pilot light	1
	2 780 01L	6	R	slt	10AX / 250V	White with pilot light	1
	0 787 10L	6	R	slt	10AX / 250V	White antibacterial	1
	0 791 01L	6	R	slt	10AX / 250V	Black mat	1
	0 994 40	6	R	slt	10AX / 250V	Black mat with pilot light	1
0 792 01L	6	R	slt	10AX / 250V	Aluminium	1	
CM11P	0 770 30	1	RM	slt	6A / 250V	White	1
CM11PB	0 770 47	1	RM	slt	6A / 250V	White	1 + 1
	0 770 33L	1	RM	slt	6A / 250V	White with pilot light	1



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/07/2024



Signature: **Julien GAUTHIER**
 Certification Officer

ANNEX

Type reference	References	Pattern	Actuating	Terminals	Rating	Colour of actuating member	Number of modules
CM16P	0 770 31	6	RM	slt	6A / 250V	White	1
	0 766 85	6	RM	slt	6A / 250V	White antibacterial	1 + 1
	0 770 30L	6	RM	slt	6A / 250V	White	1
	0 994 10	6	RM	slt	6A / 250V	White	1
	0 994 13	6	RM	slt	6A / 250V	White with pilot light	1
	2 780 30L	6	RM	slt	6A / 250V	White	1
	0 787 14L	6	RM	slt	6A / 250V	White antibacterial	1
	0 791 30L	6	RM	slt	6A / 250V	Black mat	1
	0 994 42	6	RM	slt	6A / 250V	Black mat	1
	0 792 30L	6	RM	slt	6A / 250V	Aluminium	1
	0 782 04L	6	RM	slt	6A / 250V	White antibacterial	1 + 1
	0 766 85L	6	RM	slt	6A / 250V	White antibacterial	1 + 1
CM16PB	0 770 34L	6	RM	slt	6A / 250V	White with pilot light	1
CM26B	0 770 11L	6	R	slt	10AX / 250V	White	2
	0 770 98L	6	R	slt	10AX / 250V	White	2
	0 994 01	6	R	slt	10AX / 250V	White	2
	0 994 05	6	R	slt	10AX / 250V	White with pilot light	2
	300 063	6	R	slt	10AX / 250V	White	2
	300 066	6	R	slt	10AX / 250V	White	2
	300 068	6	R	slt	10AX / 250V	White	2
	0 992 10	6	R	slt	10AX / 250V	White	2
	0 992 00	6	R	slt	10AX / 250V	White	2
	200 080	6	R	slt	10AX / 250V	White	2
	200 082	6	R	slt	10AX / 250V	White	2
	200 084	6	R	slt	10AX / 250V	White	2
	300 065	6	R	slt	10AX / 250V	White	2
	300 069	6	R	slt	10AX / 250V	White	2
	0 994 03	6	R	slt	10AX / 250V	White with pilot light	2
	0 770 98L	6	R	slt	10AX / 250V	White	2
	2 780 11L	6	R	slt	10AX / 250V	White	2
	0 787 11L	6	R	slt	10AX / 250V	White antibacterial	2
	0 791 11L	6	R	slt	10AX / 250V	Black mat	2
	0 994 41	6	R	slt	10AX / 250V	Black mat	2
	0 994 45	6	R	slt	10AX / 250V	Black mat with pilot light	2
	0 994 46	6	R	slt	10AX / 250V	Black mat with pilot light	2
	0 792 11L	6	R	slt	10AX / 250V	Aluminium / aluminium	2
	0 770 27L	6	R	slt	10AX / 250V	White antibacterial CMV	2
0 994 15	6	R	slt	10AX / 250V	White antibacterial CMV	2	



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
 Julien GAUTHIER
 Certification Officer

Date: 05/07/2024


ANNEX

Type reference	References	Pattern	Actuating	Terminals	Rating	Colour of actuating member	Number of modules
CM26P	0 770 42	6	RM	slt	6A / 250V	Aluminium with pilot light	2
	0 770 40L	6	RM	slt	6A / 250V	White	2
	0 992 02	6	RM	slt	6A / 250V	White	2
	0 992 15	6	RM	slt	6A / 250V	White	2
	0 994 11	6	RM	slt	6A / 250V	White	2
	0 994 14	6	RM	slt	6A / 250V	White with pilot light	2
	2 780 40L	6	RM	slt	6A / 250V	White	2
	0 787 15L	6	RM	slt	6A / 250V	White antibacterial	2
	0 791 40L	6	RM	slt	6A / 250V	Black mat	2
	0 994 43	6	RM	slt	6A / 250V	Black mat	2
	0 994 47	6	RM	slt	6A / 250V	Black mat with pilot light	2
	0 792 40L	6	RM	slt	6A / 250V	Aluminium	2
	0 770 43L	6	RM	slt	6A / 250V	White antibacterial label holder	2
	0 994 12	6	RM	slt	6A / 250V	White antibacterial label holder	2
CO16	0 766 77	6	CO	slt	6AX / 250V	White antibacterial	1
CO16P	0 783 76	6	COM	slt	6A / 250V	White antibacterial	1
CO26	0 770 14	6	CO	slt	10AX / 250V	White	2
CO26P	0 770 44	6	COM	slt	6A / 250V	White	2
RB6	0 770 26	6	R	slt	6AX / 250V	White rolling shutters	2
	0 996 56	6	R	slt	6AX / 250V	White rolling shutters	2
	0 787 05	6	R	slt	6AX / 250V	White antibacterial rolling shutters	2
	0 792 26	6	R	slt	6AX / 250V	Aluminium rolling shutters	2
RB6P	0 770 25	6	RM	slt	6A / 250V	White rolling shutters	2
	0 996 35	6	RM	slt	6A / 250V	White rolling shutters	2
	0 792 25	6	RM	slt	6A / 250V	Aluminium rolling shutters	2
	0 791 26L	6	RM	slt	6A / 250V	Black mat rolling shutter	2
RB4P	0 770 28	4	RM	slt	6A / 250V	White rolling shutters	2
	0 792 28	4	RM	slt	6A / 250V	Aluminium rolling shutters	2
	0 791 28L	4	RM	slt	6A / 250V	Mat Black rolling shutters	2
PE10V1	0 792 21	7	R	st	10AX / 250V	Aluminium	2
	0 770 21L	7	R	st	10AX / 250V	White	2
	0 994 09	7	R	st	10AX / 250V	White	2
	0 792 21L	7	R	st	10AX / 250V	Aluminium	2
	0 793 21L	7	R	st	10AX / 250V	Black mat	2



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr



Signature: **Julien GAUTHIER**
 Certification Officer

Date: 05/07/2024

ANNEX

Type reference	References	Pattern	Actuating	Terminals	Rating	Colour of actuating member	Number of modules
	0 770 60L	6	R	st	20AX / 250V	White with pilot light	1
	0 770 62	6	R	st	20AX / 250V	White with pilot light	1
BI20V1	0 770 63	6/2	R	st	20AX / 250V	White	2
	0 770 63L	6/2	R	st	20AX / 250V	White with pilot light	2
	0 770 64	6/2	R	st	20AX / 250V	White with pilot light	2
	0 770 92	6	R	st	20AX / 250V	White	2
	0 770 92L	6	R	st	20AX / 250V	White with pilot light	2
	0 770 94	6	R	st	20AX / 250V	White with pilot light	2

R : rocker
RM : roker momentary contact
CO : cord-operated
COM : cord-operated momentary contact
St : screw type
slt : screwless terminal
CMV : controlled mechanical ventilation
 1 0 992 04 : socket-outlet 2P+T / See licence NF012_2201
 2 0 994 24 : socket-outlet 2P+T / See licence NF012_2201

Fonction / pattern number	1, 2, 4, 6, 6/2, 7 Voir tableaux ci-dessus / See tables above
Ouverture des contacts / contacts opening (gap)	ouverture normale / normal gap petite ouverture / mini gap (CO16 - CO26 - CO26P - CO16P)
Degré de protection / degree of protection	IP 20 - IP 44 with plate 0 788 80
Mode de pose / method of mounting	Encastré / flush type Surface type with boxes for surface mounting / Type de surface avec boîtes pour montage en surface
Procédé d'installation / method of installation	design A
Type de bornes / type of terminals	Sans vis (rigide et flexible) / screwless (rigid and flexible) – A vis / screw type Voir tableaux ci-dessus / See tables above
Courant nominal / rated current (A) or (AX)	10AX, 6AX, 6A, 20AX Voir tableaux ci-dessus / See tablex above



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/07/2024



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature:  **Julien GAUTHIER**
 Certification Officer

ANNEX

Accessories :

Blank

Références References	Nombre de modules / Number of modules	Couleur / Colour
0 770 70	1	White
0 792 70	1	Aluminium
0 787 20	1	White antibacterial
0 770 71	2	White
0 792 80	2	Aluminium
0 787 21	2	White antibacterial
4 129 52	2	Grey
0 791 81L	2	Black mat

Pilot light

Références References	Spécificité / Specificity
6 650 91	Monitor light 230 V for 20AX
0 676 64	Indicator light 230V for 20AX
0 676 88	Monitor light 230 V for pattern 1 or 6 (2 lights)
0 676 85	Monitor light 230 V for pattern 6 (1 light)
0 676 84	Indicator light 230V for pattern 1
0 676 86	Indicator light 230V for pattern 6
0 676 87	Indicator light 12 / 24 / 48 V
0 676 88L	Monitor light 230 V for pattern 1 or 6 (2 lights)
0 676 85L	Monitor light 230 V for pattern 6 (1 light)
0 676 89L	Monitor light 12 / 24 / 48 V
0 676 86L	Indicator light 230V for pattern 6
0 676 87L	Indicator light 12 / 24 / 48 V
0 802 60L	Monitor light 230 V for 0 802 51
0 802 62L	Indicator light 230V for 0 802 51




LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 05/07/2024



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
Julien GAUTHIER
 Certification Officer

ANNEX

Frames

Between axes 71 with screw

References	Number of gangs or modules	specificity
0 802 50	1 module	
0 802 51	1 gang	
0 802 09	1 gang	sold by 100
0 802 59	3 modules	
0 802 52	2 gangs	
0 802 58	2 gangs horizontal	indicator lights under plate
0 802 57	2 gangs vertical	indicator lights under plate
0 802 53	3 gangs	
0 802 54	4 gangs	
0 802 64	2x2 gangs	
0 802 66	2 x 3 gangs	
0 802 68	2 x 10 modules	

Between axes 71 mm with claws

References	Number of gangs or modules
0 802 61	1 gang
0 802 69	1 gang long claws

Between axes Italy

References	Number of gang or modules
0 802 13	3 modules
0 802 14	4 modules
0 802 16	6 modules
0 802 93	3 modules CHILI

Blank

References	Number of gang or modules
0 791 04	2 gangs
0 791 06	3 gangs
0 791 10	4 gangs

Frames and boxes for thin walls

Frames References	Boxes references	Number of gang or modules	Specificity
0 802 90	0 800 10	1 module	white
0 802 92	0 800 10	2x1 module	white
0 802 91	0 800 11	2 modules	white
0 802 94	0 800 10	1 module	aluminium
0 802 95	0 800 11	2 modules	aluminium



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/07/2024



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
Julien GAUTHIER
 Certification Officer

ANNEX

Modulars

References	Number of gang or modules	Specificity
0 788 40	2 modules	cover for modular
0 801 29	2 modules	DIN rail for modular
4 129 50	2 modules	modular support

Boxes for surface mounting

References	Number of gang or modules	Specificity
0 802 80	1 gang	height 27 mm
0 802 81	1 gang	height 40 mm
0 802 82	3 modules	
0 802 83	2 gangs	vertical
0 802 84	2 gangs	horizontal
0 802 85	3 gangs	vertical
0 802 86	3 gangs	horizontal
0 802 89	4 gangs	
0 802 74	2 x 2 gangs	
0 802 76	2 x 3 gangs	
0 802 78	2 x 10 modules	

Flush-mounting workstation kits

Export references	Number of gang or modules	Specificity
0 788 72L	2 x 4 modules	white
0 788 73L	3 x 4 modules	white
0 788 74L	4 x 4 modules	white
0 790 72L	2 x 4 modules	aluminium
0 790 73L	3 x 4 modules	aluminium
0 790 74L	4 x 4 modules	aluminium

Surface-mounting workstation kits

Export references	France References	Number of gang or modules	Specificity
0 788 82L	0 788 86L	2 x 4 modules	white
0 788 83L	0 788 87L	3 x 4 modules	white
0 788 84L	0 788 88L	4 x 4 modules	white
0 790 82		2 x 4 modules	aluminium
0 790 84		4 x 4 modules	aluminium



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/07/2024



Signature:  Julien GAUTHIER
 Certification Officer


ANNEX

Cover plate
Between axes 71mm

References	Number of gangs or modules	Colour	Specificity	Frame
0 788 01	1 module	White		0 802 50
0 793 01		Aluminium		
0 788 01L	1 module	White		0 802 50
0 793 01L		Aluminium		
0 788 11	1 gang 1 module	White		0 802 51, 0 802 60, 0 802 61, 0 802 62, 0 802 69
0 788 11L	1 gang 1 module	White		
0 793 11L		Aluminium		
0 788 02	1 gang 2 modules	White	Sold by 100	0 802 51, 0 802 60, 0 802 61, 0 802 62, 0 802 69
0 788 02L	1 gang 2 modules	White		
2 778 02L		White		
0 788 99L		White		
0 787 22L		White antibacterial		
0 793 02L		Aluminium		
0 790 42L		Black mat		
0 788 03		3 modules		
0 788 03L	3 modules	White		
0 793 03L		Aluminium		
0 788 04L	2 x 2 modules	White	horizontal	0 802 52, 0 802 58
2 778 04L		White		
0 787 25L		White antibacterial		
0 793 04L		Aluminium		
0 790 44L		Black mat		
0 788 22L	2 x 2 modules	White	vertical	0 802 52, 0 802 57
2 778 22L		White		
0 787 23L		White antibacterial		
0 793 22L		Aluminium		
0 790 62L		Black mat		
0 788 14L	4 modules	White	horizontal	0 802 52, 0 802 58
2 778 14L		White		
0 787 24L		White antibacterial		
0 793 14L		Aluminium		
0 790 54L		Black mat		
0 793 25L		Aluminium		
0 793 15L		Aluminium		



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



Date: 05/07/2024

Signature: **Julien GAUTHIER**
Certification Officer

ANNEX

References	Number of gangs or modules	Colour	Specificity	Frame
0 788 06L	3 x 2 modules	White	horizontal	0 802 53
2 778 06L		White		
0 793 06L		Aluminium		
0 790 46L		Black mat		
0 788 23L	3 x 2 modules	White	vertical	0 802 53
0 793 23L		Aluminium		
0 788 16L	6 modules	White		0 802 53
2 778 16L		White		
0 787 26L		White antibacterial		
0 793 16L		Aluminium		
0 790 56L		Black mat		
0 788 18L	8 modules	White		0 802 53
0 793 18L		Aluminium		
0 790 58L		Black mat		
0 788 38L	2 x 2 x 2 modules	White		0 802 64
0 793 38L		Aluminium		
0 788 30L	2 x 5 modules	White		0 802 64
0 793 30L		Aluminium		
0 788 32L	2 x 3 x 2 modules	White		0 802 66
0 793 32L		Aluminium		
0 788 36	2 x 6 modules	White		0 802 66
0 788 36L	2 x 6 modules	White		0 802 66
0 793 36L		Aluminium		
0 790 76L		Black mat		
0 788 37L	2 x 8 modules	White		0 802 66
0 793 37L		Aluminium		
0 790 77L		Black mat		
0 788 08L	4 x 2 modules	White	horizontal	0 802 54
0 793 08L		Aluminium		
0 790 08L		Mat Black		
0 788 10L	10 modules	White		0 802 54
0 793 10L		Aluminium		
0 790 10L		Mat Black		
0 788 28L	2 x 10 modules	White		0 802 68
0 793 28L		Aluminium		



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/07/2024



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 92 100
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
 Julien GAUTHIER
 Certification Officer

ANNEX

Between axes 57

References	Number of gang or modules	Colour	Specificity	Frame
0 788 54L	2 x 2 modules	white	vertical	0 802 51, 0 802 61
0 793 54L		aluminium		
0 788 64L	2 x 2 modules	white	horizontal	0 802 51, 0 802 61, 0 802 14
0 793 64L		aluminium		
0 788 56L	3 x 2 modules	white	vertical	0 802 51, 0 802 61
0 788 66L	3 x 2 modules	white	horizontal	0 802 51, 0 802 61, 0 802 16

Between axes Italy

References	Number of gang or modules	Colour	Specificity	Frame
0 788 91	1 module	white		0 802 13, 0 802 93
0 788 92	2 modules	white	centred	0 802 13, 0 802 93
0 788 93	3 modules	white	vertical	0 802 13, 0 802 93
0 788 94	2 modules	white	separated	0 802 13, 0 802 93
0 788 90		white	blank	0 802 13, 0 802 93

IP44

References	Number of gang or modules	Colour	Specificity	Supports
0 788 80	2 modules	white antibacterial	IP44	0 802 51, 0 802 61



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/07/2024



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature:  **Julien GAUTHIER**
 Certification Officer