

CERTIFICATE

No. U6 097386 0861 Rev. 00

Holder of Certificate: **LEDVANCE GmbH**
Parking 1-5
85748 Garching
GERMANY

Certification Mark:




Product: **Electronic control gear for emergency lighting**
LED Emergency Driver

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. It is not permitted to alter the certification mark in any way. In addition, the certificate holder must not transfer the certificate to third parties. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704022601232-00

Date, 2026-03-05



(Taylor Yao)

CERTIFICATE

No. U6 097386 0861 Rev. 00

Model(s): EL KIT COMP 55V 2.3W LI MT AT 3H WT;
EL KIT COMP 55V 4W LI MT AT 3H WT

Brand Name: LEDVANCE



Parameters:

Rated Input: 220-240VAC; 50/60Hz; 50mA
Rated Output: 20-55VDC; Max. 115mA; 2.3W; Uout: 60V
[EL KIT COMP 55V 2.3W LI MT AT 3H WT];
20-55VDC; Max. 200mA; 4W; Uout: 60V
[EL KIT COMP 55V 4W LI MT AT 3H WT]
Type of Output: Constant power type
Duration: 3h
Battery: 6.4V; 1.6Ah; LiFePO4
[EL KIT COMP 55V 2.3W LI MT AT 3H WT];
6.4V; 3.2Ah; LiFePO4
[EL KIT COMP 55V 4W LI MT AT 3H WT];
Method of Installation: Independent
Protection against Electric Shock: Class II; SELV
Classification: With automatic test function
ta: 50°C
tc: 75°C

Tested according to: EN 61347-2-7:2012/A2:2022
EN 61347-1:2015/A1:2021

Production Facility(ies): 122939