

CERTIFICATE PS/25/GEN/0075



Order no.: GZ-CERT250602133-01
Test report ref.: GZES250601066601,
GZES250601066602

Issue date: 2025-08-04
Invalid from: 2029-05-22

License Holder:

F&F Filipowski sp.k.
ul. Konstantynowska 79/81, 95-200 Pabianice, Poland

Manufacturing Plant(s):

0003540496

Certified Product:

Product: Gas and Carbon Monoxide Alarm
Type/Model No.: CTLG-09-R, CTLG-09, CTLG-09-W, CTLG-08, CTLG-08-R, CTLG-08-P
Trademarks: F&F
Characteristics: See page 2
Tested according to: EN 50291-1:2018 + AC:2021-01
EN 50194-1:2009

The evaluated samples of the product fulfil the requirements of the above listed standards.
The results of this evaluation may be used by the manufacturer or his authorized agent within the European Union as basis for establishing an EC Declaration of Conformity with the requirements of Directive 2014/35/EU and affixing of the CE Marking.
The manufacturing process has been inspected prior to certification and is subject to regular supervision by SGS Group affiliates.
The license holder is authorized to mark the described product with the SGS Product Safety mark as shown above.

Remarks:

-

Signature

Mark Lohmann
Certification Manager

The test mark regulation is an integral part of this certificate.



Order no.: GZ-CERT250602133-01

Additional Information:

Characteristics:

AC 100-240V, 50Hz, max. 5W

Type B apparatus.

Alarm threshold: 30 ppm (Display), 50 ppm (Alarm sound).

Apparatus and sensor lifetime: 5 years.

Operating temperature: -10°C ~ +55°C

Sound level: ≥ 85 dB at 3m.

For other details, refer to the test report.